

Attestation

AgBB

On 09.12.2013, Eurofins Product Testing A/S received a sample of wall covering with the product name:

2500 Non-woven design2wall UV 150 matt

supplied by

Sihl GmbH

The emissions were tested according to AgBB and the guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 392-2013-00091302.

Evaluation of the emission test result according to AgBB:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m³.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m³.
 - The sum of SVOC after 28 day was below the limit of 0.1 mg/m³.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m³.
 - Formaldehyde after 28 days was below the limit of 120 µg/m³.
-

The tested product complies with the requirements of DIBt (October 2010) in combination with the NIK values from AgBB (June 2012) for use in the indoor environment.

2 July 2015



Thomas Bjerring
Analytical Service Manager



Maria Pelle
Chemist